



COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

 Rotary Compressor: Variable Frequency Drive
 MODEL DATA - FOR COMPRESSED AIR

1	Manufacturer: Ingersoll Rand		
2	Model Number: RS132n-A145	Date: 12/9/2024	
	☒ Air-cooled ☐ Water-cooled	Type: Screw	
		# of Stages: 1	
3*	Full Load Operating Pressure ^b	115	psig ^b
4	Drive Motor Nominal Rating	177	hp
5	Drive Motor Nominal Efficiency	97.0%	percent
6	Fan Motor Nominal Rating (if applicable)	10.1	hp
7	Fan Motor Nominal Efficiency	90.4%	percent
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	158.1	890	17.77
	133.1	760	17.50
	108.9	629	17.32
	85.5	496	17.26
	63.5	361	17.59
	42.8	224	19.14
9*	Total Package Input Power at Zero Flow ^{c, d}	0	kW
10	Isentropic Efficiency	82.0	percent
11	Note: Graph is only a visual representation of the data in section 8 Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity		

* For models that are tested in the CAGI Performance Verification Program, these are the items verified by the third party program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity (item 8) and Electrical Consumption (item 8) were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex C, as shown in table below.

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m^3 / min	ft^3 / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	



Member

ROT 030.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

47711010001

Rev A

ECO 1501745