



COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive MODEL DATA - FOR COMPRESSED AIR

1	Manufacturer: Ingersoll Rand		
2	Model Number: RS18ne-A145	Date:	4/13/2020
	☒ Air-cooled ☐ Water-cooled	Type:	Screw
		# of Stages:	1
3*	Full Load Operating Pressure ^b	135	psig ^b
4	Drive Motor Nominal Rating	25	hp
5	Drive Motor Nominal Efficiency	92.6	percent
6	Fan Motor Nominal Rating (if applicable)	0.7	hp
7	Fan Motor Nominal Efficiency	79.5	percent
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	23.2	105.5	22.00
	20.8	92.7	22.39
	18.3	80.5	22.77
	15.9	68.5	23.28
	13.6	56.4	24.11
	11.7	46.5	25.23
9*	Total Package Input Power at Zero Flow ^{c, d}	0	kW
10	Isentropic Efficiency	66.6	percent
11	Note: Graph is only a visual representation of the data in section 8 Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity		

* For models that are tested in the CAGI Performance Verification Program, these are the items verified by the third party program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity (item 8) and Electrical Consumption (item 8) were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex C, as shown in table below.

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\frac{m^3}{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.