

Attachment 8

Limited Export AgreementScope and Limitations of Agreement

1. This Agreement shall be used for all approved Level 2 and Level 4 Interconnection Requests according to the procedures set forth in the Maryland Standard Small Generator Interconnection Rules (COMAR 20.50.06).
2. The limited export of the DER system is implemented by the customer using a power control system (PCS) and/or utility grade relaying equipment to prevent the interconnection customer from exporting more real power than PHI's specified export limit at the point of interconnection (POI).
3. The customer's PCS used to limit the export of a DER system shall have UL 1741 CRD certification.

Export Limit

1. The export limit of the interconnection application is _____ KW.
2. The interconnection customer agrees that they will not export more real power onto the PHI distribution system greater than the export limit.
3. If the customer exports more than the export limit, PHI has the ability to disconnect the generator per section 3.4 of this interconnection agreement.
4. Mark box with "X" ☐ if below requirement #5 is required by PHI Engineering.
5. The customer shall install relaying systems and instrumentation that disconnect the customer's generator(s) in a time period of _____ cycles/seconds if the customer exports more power than the export limit at the point of interconnection.

Signatures

IN WITNESS WHEREOF, the Parties have caused this Agreement to be executed by their respective duly authorized representatives

For the Interconnection Customer:

Company Name: _____

Signature: _____

Name: _____

Title: _____

Date: _____

For EDC:

Pepco an Exelon Company

Signature: _____

Name: _____

Title: _____

Date: _____