


SEEPEX Security Updates						
Last Updated: 2 October 2025						
No.	Date of notification	Source	Bulletin	Impact	Affected SEEPEX product	Recommended action
58	9/9/2025	Siemens	SSA-503939	<p>Multiple vulnerabilities have been identified in the BIOS of the SIMATIC S7-1500 TM MFP.</p> <p>Siemens is preparing fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.</p>	SIMATIC S7-1500 TM MFP - BIOS	<p>Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk:</p> <p>Only build and run applications from trusted sources Please follow the General Security Recommendations.</p>
57	9/9/2025	Siemens	SSA-691715	<p>A vulnerability was identified in OPC Foundation Local Discovery Server which also affects Siemens products that could allow an attacker to escalate privileges under certain circumstances.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens recommends specific countermeasures for products where fixes are not, or not yet available.</p>	<p>OpenPCS 7 V9.1</p> <p>SIMATIC NET PC Software</p> <p>SIMATIC WinCC</p> <p>SIMATIC WinCC Runtime Professional</p> <p>SIMATIC WinCC Unified PC Runtime V18</p>	<p>Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk:</p> <p>Update the underlying OPC Foundation Unified Architecture Local Discovery Server (UA-LDS) to V1.04.405 or later if possible Product-specific remediations or mitigations can be found in the section Known Affected Products. Please follow the General Security Recommendations.</p>
56	8/14/2025	Rockwell Automation	SD 1734	<p>DETAILS ABOUT THE SECURITY VULNERABILITY</p> <p>Rockwell Automation used the latest version of the CVSS scoring system to evaluate the following security vulnerabilities.</p> <p>CVE-2025-7971 IMPACT</p> <p>Due to insecure processing of environment variables, there is a security vulnerability in Studio 5000 Logix Designer. If the specified path does not contain a valid file, Logix Designer crashes. However, it is possible to execute malicious code without causing a crash.</p> <p>CVSS 3.1 Base Score: 7.5</p> <p>CVSS 3.1 Vector: CVSS:3.1/AV:L/AC:H/PR:L/UI:C/H/I:H/A:H</p> <p>CVSS 4.0 Base Score: 7.3</p> <p>CVSS 4.0 vector: CVSS:4.0/AV:L/AC:H/AT:N/PR:L/UI:P/VC:H/VI:H/VA:H/SC:N/SI:N/SA:N</p> <p>CWE: CWE-20: Improper Input Validation</p> <p>Known Exploited Vulnerabilities (KEV) database: No</p>	Studio 5000 Logix Designer 36.00.02	<p>Remedial measures and workarounds</p> <p>Users should update to the corrected version if possible. If users who use the affected software cannot upgrade the version, best security practices should be applied.</p>
55	8/14/2025	Rockwell Automation	SD 1732	<p>Rockwell Automation has used the latest version of the CVSS scoring system to assess the following vulnerabilities.</p> <p>CVE-2025-7353 IMPACT</p> <p>A security issue exists due to the web-based debugger agent enabled on released devices. If a specific IP address is used to connect to the WDB agent, attackers can remotely create memory dumps, modify memory, and control execution flow.</p> <p>CVSS 3.1 Base Score: 9.8</p> <p>CVSS 3.1 Vector: CVSS:3.1/AV:N/AC:L/PR:N/UI:N/S:U/C:H/I:H/A:H</p> <p>CVSS 4.0 Base Score: 9.3</p> <p>CVSS 4.0 Vector: CVSS:4.0/AV:N/AC:L/AT:N/PR:N/UI:N/VC:H/VI:H/VA:H/SC:N/SI:N/SA:N</p> <p>CWE: CWE-1188: Initializing a resource with an insecure default setting</p> <p>Known Exploited Vulnerabilities Database (KEV): No</p>	1756-EN2T/D,1756-EN2F/C, 1756-EN2TR/C, 1756-EN3TR/B, 1756-EN2TP/A Version 11.004 or below	<p>Remedial measures and workarounds</p> <p>Users should update to the corrected version if possible. If users who use the affected software cannot upgrade the version, best security practices should be applied.</p>

54	8/12/2025	Schneider Electric	CVE-2025-6625	<p>Schneider Electric has identified a security vulnerability in its Modicon M340, BMXNOR0200H: Modicon M340 X80 Ethernet communication modules, BMXNGD0100: M580 Global Data module, BMXNOC0401: Modicon M340 X80 Ethernet communication modules, BMXNOE0100: Modbus/TCP Ethernet Modicon M340 module, BMXNOE0110: Modbus/TCP Ethernet Modicon M340 FactoryCast module products.</p> <p>If the fix below is not applied, there is a risk of a denial-of-service attack that could result in the devices becoming unavailable</p>	<p>Modicon M340 All versions BMXNOE0100: Modbus/TCP Ethernet Modicon M340 module Versions prior to SV3.60 BMXNOE0110: Modbus/TCP Ethernet Modicon M340 FactoryCast module Versions prior to SV6.80</p>	<p>We strongly recommend the following best practices for industrial cybersecurity.</p> <ul style="list-style-type: none"> • Place control and security system networks and remote devices behind firewalls and isolate them from the corporate network. • Install physical controls to prevent unauthorized personnel from accessing your industrial control and security systems, components, peripherals, and networks. <p>Security Advisory from Schneider Electric August 12, 2025 Document Reference Number – SEVD-2025-224-05 Page 4 of 5 Public / TLP: Released</p> <ul style="list-style-type: none"> • Keep all controllers in locked cabinets and never leave them in “program” mode. • Never connect programming software to any network other than the network intended for that device. • Scan all methods of mobile data exchange with the isolated network, such as CDs, USB sticks, etc., before use in the terminals or at a node connected to these networks. • Never allow mobile devices that have been connected to a network other than the intended network to connect to the security or control networks without proper cleaning. • Minimize network exposure for all control system devices and systems and ensure that they are not accessible via the Internet. • If remote access is required, use secure methods such as Virtual Private Net Please note that VPNs may have vulnerabilities and should be updated to the latest available version. Also note that VPNs are only as secure as the devices connected to them. <p>For more information, see Schneider Electric's recommended cybersecurity measures.</p>
53	8/12/2025	Schneider Electric	CVE-2024-5056	<p>Schneider Electric is aware of a security vulnerability in its Modicon M340, BMXNOE0100, and BMXNOE0110 products.</p> <p>The Modicon M340 is a programmable logic controller; BMXNOE0100 and BMXNOE0110 are network modules used with the Modicon M340.</p> <p>If the workarounds listed below are not implemented, users may not be able to update the device firmware and the web server may not function properly. The operation of BMXNOE and Modicon M340 is not affected by this security vulnerability.</p> <p>August update: Workarounds are available for BMXNOE0100 (Modbus/TCP Ethernet Modicon M340 module) and BMXNOE0110 (Modbus/TCP Ethernet Modicon M340 FactoryCast module).</p>	<p>Modicon M340 All versions BMXNOR0200H: Ethernet / Serial RTU Module All versions BMXNGD0100: M580 Global Data module All versions BMXNOC0401: Modicon M340 X80 Ethernet Communication modules All versions BMXNOE0100: Modbus/TCP Ethernet Modicon M340 module Versions prior to 3.60 BMXNOE0110: Modbus/TCP Ethernet Modicon M340 FactoryCast module Versions prior to 6.80</p>	<p>General security recommendations</p> <p>We strongly recommend the following best practices for industrial cybersecurity.</p> <ul style="list-style-type: none"> • Place networks for control and safety systems and remote devices behind firewalls and isolate them from the corporate network. • Install physical controls to prevent unauthorized personnel from accessing your industrial control and security systems, components, peripherals, and networks. • Keep all controllers in locked cabinets and never leave them in “program” mode. • Never connect programming software to any network other than the one intended for that device. • Scan all methods of mobile data exchange with the isolated network, such as CDs, USB sticks, etc., before using them in terminals or other nodes connected to these networks. • Never allow mobile devices that have been connected to a network other than the intended network to connect to the security or control networks without proper cleaning. <p>Security Advisory from Schneider Electric June 24, 2011 (August 25, 2012) Document Reference Number – SEVD-2024-163-01(v2.0.0) Page 4 of 5 Public / TLP: Approved</p> <ul style="list-style-type: none"> • Minimize network exposure for all control system devices and systems and ensure that they are not accessible via the Internet. • If remote access is necessary, use secure methods such as virtual private networks (VPNs). Note that VPNs can have vulnerabilities and should be updated to the latest available version. Also note that VPNs are only as secure as the connected devices.
52	8/18/2025	Siemens	SSA-711309	<p>🔗</p> <p>The OPC UA implementations (ANSI C and C++) used in several SIMATIC products contain a denial-of-service vulnerability that could allow an unauthenticated attacker to create a denial-of-service condition by sending a specially crafted certificate.</p> <p>Siemens has released new versions for several affected products and recommends updating to the latest versions. Siemens recommends specific countermeasures for products for which no fixes are available or are not yet available.</p>	<p>SIMATIC WinCC Unified OPC UA Server</p> <p>SIMATIC WinCC OPC UA Client</p> <p>SIMATIC WinCC Runtime Professional</p> <p>SIMATIC S7-1500 CPU family (incl. related ET200 CPUs and SIPLUS variants)</p>	<p>Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk:</p> <p>Disable the OPC UA function if it is not in use.</p> <p>Product-specific mitigations or workarounds can be found in the Affected Products and Solutions section.</p> <p>Please note the general security recommendations.</p>
51	8/12/2025	Siemens	SSA-460466	<p>A vulnerability in TIA Project Server and TIA Portal could allow an attacker to cause a denial-of-service condition.</p> <p>Siemens has released new versions for several affected products and recommends updating to the latest versions. Siemens is preparing further corrective versions and recommends countermeasures for products for which no corrections are available or are not yet available.</p>	<p>Totally Integrated Automation Portal (TIA Portal) V18 & V20</p>	<p>Product-specific remedies or protective measures can be found in the section “Known affected products.”</p> <p>Please follow the general security recommendations.</p>

50	8/12/2025	Siemens	SSA-353002	<p>The SCALANCE XB-200/XC-200/XP-200/XF-200BA/XR-300WG family is affected by several security vulnerabilities. CVE-2023-44318 and CVE-2023-44321 were previously published as part of SSA-699386.</p>	SCALANCE XB-200/XC-200/XP-200/XF-200BA/XR-300WG Familie.	<p>As a general security measure, Siemens strongly recommends protecting network access to the devices with appropriate mechanisms. To operate the devices in a protected IT environment, Siemens recommends configuring the environment in accordance with the Siemens operating guidelines for industrial security (download: https://www.siemens.com/cert/operational-guidelines-industrial-security) and to follow the recommendations in the product manuals. For more information on industrial security from Siemens, visit: https://www.siemens.com/industrialsecurity</p>
49	8/12/2025	Siemens	SSA-800126	<p>Affected products do not properly sanitize user-controllable input when parsing files. This could allow an attacker to cause a type confusion and execute arbitrary code within the affected application.</p> <p>Siemens has released new versions for several affected products and recommends updating to the latest versions. Siemens is preparing further corrective versions and recommends specific countermeasures for products for which no corrections are available or are not yet available.</p> <p>Siemens has released products based on the Totally Integrated Automation Portal (TIA Portal) V20 that are not affected by CVE-2024-49849. For more information, see the “Additional Information” section below.</p>	<p>SIMATIC S7-PLCSIM V16</p> <p>Totally Integrated Automation Portal V16, V17, V18 (TIA Portal)</p>	<p>Siemens has identified the following specific workarounds and remedies that customers can apply to mitigate the risk:</p> <p>CVE-2024-49849: Avoid opening untrusted files from unknown sources in affected products.</p>
41	6/10/2025	Siemens	SSA-858251	<p>The products listed below contain two authentication bypass vulnerabilities that could allow an attacker to gain access to the data managed by the server.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends countermeasures for products where fixes are not, or not yet available.</p>	OPC UA	<p>Product-specific remediations or mitigations can be found in the section Affected Products and Solution.</p> <p>Please follow the General Security Recommendations.</p> <p>GENERAL SECURITY RECOMMENDATIONS</p> <p>As a general security measure, Siemens strongly recommends to protect network access to devices with appropriate mechanisms. In order to operate the devices in a protected IT environment, Siemens recommends to configure the environment according to Siemens’ operational guidelines for Industrial Security (Download: https://www.siemens.com/cert/operational-guidelines-industrial-security), and to follow the recommendations in the product manuals. Additional information on Industrial Security by Siemens can be found at: https://www.siemens.com/industrialsecurity</p>
40	13.05.2025	Siemens	SSA-876787	<p>Several SIMATIC S7-1500 and S7-1200 CPU versions are affected by an open redirect vulnerability that could allow an attacker to make the web server of affected devices redirect a legitimate user to an attacker-chosen URL. For a successful attack, the legitimate user must actively click on an attacker-crafted link.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.</p>	<p>SIMATIC S7-1200 / S7-1500 CPUSiemens can be found at: https://www.siemens.com/industrialsecurity</p>	<p>Siemens has identified the following specific workarounds and mitigations that customers can apply to</p> <p>reduce the risk:</p> <ul style="list-style-type: none">• Do not click on links from unknown sources. <p>Product-specific remediations or mitigations can be found in the section Affected Products and Solution.</p> <p>Please follow the General Security Recommendations.</p> <p>GENERAL SECURITY RECOMMENDATIONS</p> <p>As a general security measure, Siemens strongly recommends to protect network access to devices with appropriate mechanisms. In order to operate the devices in a protected IT environment, Siemens recommends to configure the environment according to Siemens’ operational guidelines for Industrial Security (Download: https://www.siemens.com/cert/operational-guidelines-industrial-security), and to follow the recommendations in the product manuals. Additional information on Industrial Security by Siemens can be found at: https://www.siemens.com/industrialsecurity</p>

39	5/13/2025	Siemens	SSA-054046	<p>Several SIMATIC S7-1500 CPU versions are affected by an authentication bypass vulnerability that could allow an unauthenticated remote attacker to gain knowledge about actual and configured maximum cycle times and communication load of the CPU.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends countermeasures for products where fixes are not, or not yet available.</p>	SIMATIC S7-1500 CPU SIMATIC ET 200SP	<p>Product-specific remediations or mitigations can be found in the section Affected Products and Solution.</p> <p>Please follow the General Security Recommendations.</p> <p>GENERAL SECURITY RECOMMENDATIONS</p> <p>As a general security measure, Siemens strongly recommends to protect network access to devices with appropriate mechanisms. In order to operate the devices in a protected IT environment, Siemens recommends to configure the environment according to Siemens' operational guidelines for Industrial Security (Download: https://www.siemens.com/cert/operational-guidelines-industrial-security), and to follow the recommendations in the product manuals. Additional information on Industrial Security by Siemens can be found at: https://www.siemens.com/industrialsecurity</p>
38	4/8/2025	Schneider Electric Security Notification	CVE-2024-8936	<p>Schneider Electric is aware of multiple vulnerabilities in its Modicon Controllers M340 / Momentum / MC80 products. Modicon PAC control and monitor industrial operations. Failure to apply the provided remediations/mitigations below may risk unauthorized access to the controller, which could result in the possibility of denial of service and loss of confidentiality, integrity of the controller. April 2025 Update: A remediation is now available for Modicon Momentum Unity M1E ProcessorVersion prior to SV3.65</p>	Modicon M340 CPU (part numbers BMXP34*)	Version SV3.65 of Modicon M340 firmware includes a fix for these vulnerabilities
37	4/8/2025	Schneider Electric Security Notification	CVE-2020-28895	<p>Schneider Electric is aware of multiple memory allocation vulnerabilities dubbed 'BadAlloc', disclosed by Microsoft on April 29, 2021. The impact of a successful exploitation of the vulnerabilities may result in denial of service, or remote code execution, depending on the context. April 2025 Update: A remediation is available for BMECRA31210, BMXCRA31200, BMXCRA31210 (Page 13) and mitigations for this product have been updated.</p>	Modicon M340 CPU (BMXP34*) v3.40 and prior	Version 3.50 of Modicon M340 includes a fix for these vulnerabilities
36	4/8/2025	Siemens Security Advisory by Siemens ProductCERT	SSA-876787	<p>Several SIMATIC S7-1500 and S7-1200 CPU versions are affected by an open redirect vulnerability that could allow an attacker to make the web server of affected devices redirect a legitimate user to an attacker-chosen URL. For a successful attack, the legitimate user must actively click on an attacker-crafted link.</p>	SIMATIC S7-1200 CPU 1215C DC/DC/DC (6ES7215-1AG40-0XB0) All versions < V4.7	Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.
35	4/8/2025	Siemens Security Advisory by Siemens ProductCERT	SSA-725549	<p>A vulnerability exists in affected products that could allow remote attackers to affect the availability of the devices under certain conditions.</p> <p>The integrated ICMP services in the underlying TCP/IP stack is vulnerable to a denial of service attack through specially crafted ICMP packets. A successful attack will impact the availability of ICMP services on affected products for a limited time before it restores itself after the attack ceases. Other communication services are not affected by this vulnerability.</p>	SIMATIC ET 200SP IM 155-6 PN/2 HF (6ES7155-6AU01-0CN0) All versions SIMATIC S7-1200 CPU 1215C DC/DC/DC (6ES7215-1AG40-0XB0) All versions < V4.4	Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.
34	4/8/2025	Siemens Security Advisory by Siemens ProductCERT	SSA-195895	<p>The webserver of several SIMATIC products is affected by a user enumeration vulnerability that could allow an unauthenticated remote attacker to identify valid usernames.</p>	SIMATIC S7-1200 CPU 1215C DC/DC/DC (6ES7215-1AG40-0XB0) All versions < V4.7	Siemens has released new versions for the affected products and recommends to update to the latest versions.
33	3/11/2025	Siemens	SSA-858251	<p>The products listed below contain two authentication bypass vulnerabilities that could allow an attacker to gain access to the data managed by the server.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends countermeasures for products where fixes are not, or not yet available.</p>	Totally Integrated Automation Por-tal (TIA Portal) V18, V19	<p>Product-specific remediations or mitigations can be found in the section Affected Products and Solution.</p> <p>Please follow the General Security Recommendations.</p>
32	3/11/2025	Siemens	SSA-876787	<p>Several SIMATIC S7-1500 and S7-1200 CPU versions are affected by an open redirect vulnerabilty that could allow an attacker to make the web server of affected devices redirect a legitimate user to an attacker-chosen URL. For a successful attack, the legitimate user must actively click on an attacker-crafted link.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends specific counter-measures for products where fixes are not, or not yet available.</p>	S7-1200 CPU / S7-1500 CPU	<p>As a general security measure, Siemens strongly recommends to protect network access to devices with appropriate mechanisms. In order to operate the devices in a protected IT environment, Siemens recommends to configure the environment according to Siemens' operational guidelines for Industrial Security (Download: https://www.siemens.com/cert/operational-guidelines-industrial-security), and to follow the recommendations in the product manuals. Additional information on Industrial Security by Siemens can be found at: https://www.siemens.com/industrialsecurity</p>
31	3/11/2025	Siemens	SSA-054046	<p>Several SIMATIC S7-1500 CPU versions are affected by an authentication bypass vulnerability that could allow an unauthenticated remote attacker to gain knowledge about actual and configured maximum cycle times and communication load of the CPU.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends countermeasures for products where fixes are not, or not yet available.</p>		<p>As a general security measure, Siemens strongly recommends to protect network access to devices with appropriate mechanisms. In order to operate the devices in a protected IT environment, Siemens recommends to configure the environment according to Siemens' operational guidelines for Industrial Security (Download: https://www.siemens.com/cert/operational-guidelines-industrial-security), and to follow the recommendations in the product manuals. Additional information on Industrial Security by Siemens can be found at: https://www.siemens.com/industrialsecurity</p>

30	2/11/2025	Schneider	Vulnerabilities Details	<p>The Modicon Programmable Automation controllers are used for complex networked communication, display and control applications</p> <p>Failure to apply the mitigations or remediations provided below may risk execution of unsolicited command on the PLC which could result in a loss of availability of the controller</p> <p>February 2025 Update: Correction of vulnerabilities impacting Quantum Safety processor</p>	Modicon Controller M340, M580	Update Software and Firmware and Rebuild the Projects
29	2/11/2025	Siemens	SSA-195895	<p>The webserver of several SIMATIC products is affected by a user enumeration vulnerability that could allow an unauthenticated remote attacker to identify valid usernames.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.</p>	<p>SIMATIC S7-1200 CPU family V4 (incl. SIPLUS variants)</p> <p>SIMATIC S7-1500 CPU family (incl. related ET200 CPUs and SIPLUS variants)</p> <p>SIMATIC S7-PLCSIM Advanced</p> <p>All versions >= V6.0 < V7.0</p>	<p>Update to V4.7 or later version</p> <p>Update to V3.1.2 or later version.Disable HTTP (port 80/tcp) and provide web service access through HTTPS (port 443/tcp) only; the vulnerability is considered as only exploitable via HTTP</p> <p>Update to V7.0 or later version</p> <p>Disable HTTP (port 80/tcp) and provide web service access through HTTPS (port 443/tcp) only; the vulnerability is considered as only exploitable via HTTP</p>
28	2/11/2025	Siemens	SSA-224824	<p>SIMATIC S7-1200 CPU family before V4.7 is affected by two denial of service vulnerabilities.</p> <p>Siemens has released new versions for the affected products and recommends to update to the latest versions.SIMATIC S7-1200 CPU family before V4.7 is affected by two denial of service vulnerabilities.</p> <p>Siemens has released new versions for the affected products and recommends to update to the latest versions.</p>	SIMATIC S7-1200 CPU family V4 (incl. SIPLUS variants)	Update to V4.7 or later version
27	2/11/2025	Siemens	SSA-342348	<p>Affected products do not correctly invalidate user sessions upon user logout.</p> <p>This could allow a remote unauthenticated attacker, who has obtained the session token by other means, to re-use a legitimate user's session even after logout.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens recommends countermeasures for products where fixes are not, or not yet available.</p>	<p>TIA Administrator</p> <p>All versions < V3.0.4</p> <p>Totally Integrated Automation Portal (TIA Portal)</p>	<p>Update to V3.0.4 or later version</p> <p>Update to V19 Update 1 or later version</p>
26	2/11/2025	Siemens	SSA-349422	<p>A vulnerability in the affected products could allow an unauthorized attacker with network access to perform a denial-of-service attack resulting in loss of real-time synchronization.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens recommends specific countermeasures for products where fixes are not, or not yet available.</p>	SIMATIC ET 200SP IM 155-6 PN HF (incl. SIPLUS variants)	Update to V4.2.0 or later version
25	2/11/2025	Siemens	SSA-712929	<p>A vulnerability in the openssl component (CVE-2022-0778, [0]) could allow an attacker to create a denial of service condition by providing specially crafted elliptic curve certificates to products that use a vulnerable version of openssl.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends countermeasures for products where fixes are not, or not yet available.</p>	<p>SCALANCE XC208</p> <p>SIMATIC CP 1243-1</p> <p>SIMATIC ET 200SP communications modules (CP 1542SP-1, CP 1542SP-1 IRC and CP 1543SP-1, incl. SIPLUS variants)</p> <p>SIMATIC S7-1200 CPU family (incl. SIPLUS variants)</p> <p>SIMATIC S7-1500 CPU 1513R-1 PN</p> <p>SIMATIC S7-PLCSIM Advanced</p> <p>SIMATIC WinCC V7/V8</p> <p>Totally Integrated Automation Portal (TIA Portal) V16</p>	<p>Update to V4.4 or later version</p> <p>Update to V3.4.29 or later version</p> <p>Update to V2.2.28 or later version</p> <p>Update to V4.6.0 or later version</p> <p>Update to V2.9.7 or later version</p> <p>Update to V5.0 or later version</p> <p>Update to V7.5 SP2 Update 16 or later version</p> <p>Currently no fix is planned</p>
24	1/14/2025	Siemens	SSA-876787	<p>Several SIMATIC S7-1500 and S7-1200 CPU versions are affected by an open redirect vulnerability that could allow an attacker to make the web server of affected devices redirect a legitimate user to an attacker-chosen URL. For a successful attack, the legitimate user must actively click on an attacker-crafted link.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.</p>	<p>SIMATIC S7-1500 CPU family (incl. related ET200 CPUs and SIPLUS variants)</p> <p>SIMATIC ET 200SP Open Controller CPU 1515SP PC2 (incl. SIPLUS variants)</p> <p>SIMATIC S7-1500 Software Controller</p>	<p>Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk:</p> <p>Do not click on links from unknown sources.</p> <p>Product-specific remediations or mitigations can be found in the section Affected Products and Solution.</p> <p>Please follow the General Security Recommendations.</p>

23	1/14/2025	Siemens	SSA-730482	<p>A vulnerability in the login dialog box of SIMATIC WinCC could allow a local attacker to cause a denial of service condition in the runtime of the SCADA system.</p> <p>Siemens has released new versions for the affected products and recommends to update to the latest versions.</p>	<p>SIMATIC WinCC Runtime Professional</p> <p>SIMATIC PCS 7</p>	<p>Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk:</p> <p>Activate SIMATIC Logon in the User Administrator of the SIMATIC PCS 7 Operator Stations</p> <p>Product-specific remediations or mitigations can be found in the section Affected Products and Solution.</p> <p>Please follow the General Security Recommendations.</p>
22	1/14/2025	Siemens	SSA-711309	<p>The OPC UA implementations (ANSI C and C++) as used in several SIMATIC products contain a denial of service vulnerability that could allow an unauthenticated remote attacker to create a denial of service condition by sending a specially crafted certificate.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens recommends specific countermeasures for products where fixes are not, or not yet available.</p>	<p>SIMATIC WinCC Unified OPC UA Server</p> <p>SIMATIC WinCC OPC UA Client</p> <p>SIMATIC WinCC Runtime Professional</p> <p>SIMATIC S7-1500 CPU family (incl. related ET200 CPUs and SIPLUS variants)</p>	<p>Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk:</p> <p>Disable the OPC UA feature, if not used</p> <p>Product-specific remediations or mitigations can be found in the section Affected Products and Solution.</p>
21	1/14/2025	Siemens	SSA-413565	<p>Multiple SCALANCE devices are affected by several vulnerabilities that could allow an attacker to inject code, retrieve data as debug information as well as user CLI passwords or set the CLI to an irresponsible state.</p> <p>Siemens has released updates for the affected products and recommends to update to the latest versions.</p>	<p>SCALANCE XB-200/XC-200/XP-200/XF-200BA/XR-300WG family</p>	<p>Product-specific remediations or mitigations can be found in the section Affected Products and Solution.</p> <p>Please follow the General Security Recommendations.</p>
20	12/10/2024	Siemens	SSA-711309	<p>The OPC UA implementations (ANSI C and C++) as used in several SIMATIC products contain a denial of service vulnerability that could allow an unauthenticated remote attacer to create a denial of service condition by sending a specially crafted certificate.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.</p>	<p>SIMATIC S7-1500 CPU family (incl. related ET200 CPUs and SIPLUS variants)</p> <p>SIMATIC Win CC OPC UA Client</p> <p>SIMATIC WinCC Runtime Professional</p> <p>SIMATIC WinCC Unified OPC UA Server</p>	<p>Update to V2.0.0.1 or later version</p> <p>See further recommendations from section Workarounds and Mitigations</p>
19	12/10/2024	Siemens	SSA-876787	<p>Several SIMATIC S7-1500 and S7-1200 CPU versions are affected by an open redirect vulnerability that could allow an attacker to make the web server of affected devices redirect a legitimate user to an attacker-chosen URL. For a successfull attack, the legitimate user must actively click on an attacker-crafted link.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Simens is preparing further fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.</p>	<p>SIMATIC S7-1500 Software Controller</p>	<p>Currently no fix available</p> <p>See further recommendations from section Workarounds and Mitigations</p>
18	11/12/2024	Siemens	SSA-871035	<p>Affected products do not properly sanitize user-controllable input when parsing files. This could allow an attacker to cause a type confusion and execute arbitrary code within the affected application.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends countermeasures for products where fixes are not, or not yet available.</p>	<p>SIMATIC S7-PLCSIM V16</p> <p>Totally Integrated Automation Portal V16, V17, V18 (TIA Portal)</p>	<p>No solution available yet.</p> <p>Please see here for further information.</p>
17	10/8/2024	Siemens	SSA-054046	<p>Several SIMATIC S7-1500 CPU versions are affected by an authentication bypass vulnerability that could allow an unauthenticated remote attacker to gain knowledge about actual and configured maximum cycle times and communication load of the CPU.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends countermeasures for products where fixes are not, or not yet available.</p>	<p>All S7-1500 CPUs</p>	<p>Product-specific remediations or mitigations can be found in the section Affected Products and Solutions. Please follow the General Security Recommendations</p>
16	10/8/2024	Siemens	SSA-876787	<p>Several SIMATIC S7-1500 and S7-1200 CPU versions are affected by an open redirect vulnerability that could allow an attacker to make the web werver of affected devices redirect a legitimate user to an attacker-chosen URL. Fo a successful attack, the legitimate user needs to actively click on an attacker-crafted link.</p> <p>Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens is preparing further fix versions and recommends specific countermeasures for products where fixes are not, or not yet available.</p>	<p>Simatic S7-1200 CPU Family</p> <p>Simatic S7-1500 CPU Family</p>	<p>Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk</p> <p>Do not click on links from unknown sources.</p> <p>Product-specific remeditations or mitigations can be found in the section Affected Products and Solutions. Please follow the General Security Recommendations.</p>
15	8/13/2024	Rockwell Automation	SD 1685	<p>A denial-of-service vulnerability exists in the affected product. This vulnerability occurs when a malformed PCCC message is received, causing a failure in the controller.</p>	<p>ControlLogix/GuardLogix 5580 and Compact-Logix/Compact GuardLogix® 5380 Controller</p>	<p>Update to latest firmware revision.</p> <p>Restrict communication to CIP objects 103 (0x67)</p>

14	7/9/2024	Siemens	SSA-779936	Affected applications do not properly restrict the .NET BinaryFormatter when deserializing user controllable input. This could allow an attacker to cause a type confusion and execute arbitrary code within the affected application.	Totally Integrated Automation Portal (TIA Portal) before V19	Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk: Avoid opening untrusted files from unknown sources in affected products
13	7/9/2024	Siemens	SSA-473245	A vulnerability in affected devices could allow an attacker to perform a denial of service attack if a large amount of specially crafted UDP packets are sent to the device. Siemens has released new versions for several affected products and recommends to update to the latest versions. Siemens recommends specific counter measures for products where fixes are not, or not yet available.	Simatic S7-1200 CPU Family, Simatic S7-1500 Family, ET200SP	Siemens has identifid the following specific workarounds and mitigations that customers cann apply to reduce the risk: Restrict network access to affected devices
12	6/11/2024	Siemens	SSA-319319	TIA Administrator creates temporary download files in a directory with insecure permissions. This could allow any authenticated attacker on Windows to disrupt the update process.	TIA-Administrator <3.2	Siemens has released a new version for TIA Administrator and recommends to update to the latest version. Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk. Remove write permissions for non-administrative users on files and folders located under the installation path
11	6/11/2024	Siemens	SSA-353002	The SCALANCE XB-200/XC-200/XP-200/XF-200BA/XR-300WG group is affected by multiple vulnerabilities. CVE-2023-44318 and CVE-2023-44321 were previously published as part of SSA-699386.	SCALANCE XB-200/XC-200/XP-200/XF-200BA/XR-300WG group.	As a general security measure, Siemens strongly recommends to protect network access to devices with appropriate mechanisms. In order to operate the devices in a protected IT environment, Siemens recommends to configure the environment according to Siemens' operational guidelines for Industrial Security (Download: https://www.siemens.com/cert/operational-guidelines-industrial-security), and to follow the recommendations in the product manuals. Additional information on Industrial Security by Siemens can be found at: https://www.siemens.com/industrialsecurity
10	6/11/2024	Siemens	SSA-711309	Denial of Service Vulnerability in the OPC UA Implementations of SIMATIC Products	All SEEPEX control featuring the following SIEMENS Software: SIMATIC S7-12xx SIMATIC S7-15xx SIMATIC ET 200SP	Currently no fix available/ Update to latest version
9	5/21/2024	Rockwell Automation	SD1672	IMPORTANT NOTICE: Rockwell Automation reiterates the instruction to its customers to disconnect devices from the Internet to protect against cyber threats Due to heightened geopolitical tensions and hostile cyber activity around the world, Rockwell Automation urges all customers to IMMEDIATELY check if their devices are connected to the public Internet and, if so, to urgently remove that connection for devices that are not specifically designed for a public Internet connection.	All SEEPEX controls with Rockwell Automation Hardware	Due to heightened geopolitical tensions and adversarial cyber activity globally, Rockwell Automation is issuing this notice urging all customers to take IMMEDIATE action to assess whether they have devices facing the public internet and, if so, urgently remove that connectivity for devices not specifically designed for public internet connectivity.
8	5/14/2024	Siemens	SSA-592380	A vulnerability has been discovered in the SIMATIC S7-1500 CPU family and related products that could allow an attacker to trigger a denial of service condition. In order to exploit the vulnerability, an attacker must have access to the affected devices on port 102/tcp.	All SEEPEX controls with the following SIEMENS hardware: SIMATIC S7-1500 CPU 1513R-1 PN (6ES7513-1RL00-0AB0)	No solution is currently planned
7	2/13/2024	Siemens	SSA-711309	Denial of Service Vulnerability in the OPC UA Implementations of SIMATIC Products	All SEEPEX controls featuring the following SIEMENS Software: SIMATIC S7-12xx SIMATIC S7-15xx SIMATIC ET 200SP	Currently no fix available / Update to latest version
6	12/12/2023	Siemens	SSA-887801	Information disclosure to LOCAL attacker to the access level password of the SIMATIC S7-1200 and S7-1500 CPUs	All SEEPEX controls featuring the following SIEMENS hardware: SIMATIC S7-12xx SIMATIC S7-15xx	Exclusion of local attackers and/or firmware update to V19 or later version
5	12/12/2023	Siemens	SSA-398330	Multiple Vulnerabilities in SIMATIC S7-1500 CPUs of GNU/Linux subsystem	All SEEPEX controls featuring the following SIEMENS hardware: SIMATIC S7-15xx	See SSA-398330
4	12/12/2023	Siemens	SSA-592380	Denial of Service Vulnerability in SIMATIC S7- 1500 CPUs via port 102 tcp	All SEEPEX controls featuring the following SIEMENS hardware: SIMATIC S7-15xx	Firmware update to V3.1.0 or later version
3	12/9/2023	Siemens	SSA-711309	Denial of Service Vulnerability in the OPC UA Implementations of SIMATIC Products	All SEEPEX controls on SIEMENS PLCs that are connected to a SEEPEX Gateway (e.g. SPG)	Firmware update to V8.1. SP1 or later version
2	11/14/2023	Siemens	SSA-699386	Multiple Vulnerabilities on SIEMENS SCALANCE Routern	All SEEPEX control cabinets featuring the following SIEMENS hardware: SCALANCE XB-200, XC- 200, XP-200, XF-200BA and XR-300WG	Firmware update to V4.5 or later version

1	5/28/2021	Siemens	SSA-434534	Memory Protection Bypass Vulnerability in SIMATIC S7-1200 and S7-1500 CPU Families	<div>All SEEPEX controls featuring the following SIEMENS hardware:</div> <div>SIMATIC S7-12xx</div> <div>SIMATIC S7-15xx</div> <div>SIMATIC ET 200SP Open Controller CPU</div>	<div>SIMATIC S7-12xx:</div> <div>firmware update to V4.5 or later version</div> <div>SIMATIC S7-15xx:</div> <div>firmware update to V2.9.2 or later version</div>
---	-----------	---------	----------------------------	------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------